

200ppm indicates 100 cfm of fresh air ventilation. 850 ppm indicates 50 cfm of fresh air ventilation. The number of occupants are not stated. This home several Ultra-Aire whole house ventilating dehumidifiers set to ventilate on The data logger is located in the open center part of the home. The low levels of CO2 are when the doors are open. 650 ppm CO2 is 200 ppm above the 450 ppm outside the home. One occupant raising the indoor CO2